



Administrative Office of the Courts

Operations Division

AMENDMENT #3 REQUEST FOR PROPOSALS Courtroom Construction- Salisbury, Maryland RFP K20-0084-49

The following questions for the above referenced RFP were received by e-mail and are answered and posted for all prospective Offerors. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. The following changes/additions are listed below; new language has been underlined and language deleted has been marked with a strikeout (ex. ~~language deleted~~)

1. Modify Page 12- Statement of Work/ Deliverables

- B. Benches should be a style more similar if possible to the style in Courtroom #3 and maximize the seating capacity of each courtroom. Current benches are 11' 2 1/2" long, 6 benches will remain this length. 20 Gallery benches will be longer and start 4" from the wall. Account for handicap seating. Center isle should remain close to the current width, but no smaller. The 1st row bench will move to behind the Galley rail.
- C. Galley rails need to match the existing courtroom Galley rails in Courtrooms 1 & 2. Galley rails will start 4" from the wall. Center isle should remain close to the current width, but no smaller. The Galley rail will move forward of the 1st row bench.

Modify Page 14- Statement of Work/ Deliverable

- 7. All exposed wood:
 - a. Type: ~~Maple~~ Birch

2. Modify Page 45- Price Proposal Form

The AOC will consider price adjustments for unforeseen circumstances due to not having site visits.

3. Attachments

The AOC provided additional drawings for the Courtroom Construction-Salisbury. Courtroom #3 attachment is the new bench style reference.

Issued by Alisha Allmond
Procurement Officer
April 21, 2020