



# Administrative Office of the Courts

---

## Operations Division

### Questions/Responses No. 1 to the

### Invitation for Bids (IFB) K21-0067-42C

### District Court Bullet Resistant Glass Supply & Install

Ladies and Gentlemen:

The following questions for the above referenced RFP were received by e-mail and are answered and posted for all prospective Offerors. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Offeror asking the question.

1. Question: Are the frames for the Ocean City District Court the only frames that will be supplied by the contractor? ?  
Response: No, Cumberland location as well.
2. Question: Will the speak throughs have a complete arched cutout and subsequently behind the opening will be a larger arched BR glazing slightly larger to impede a full opening?  
Response: Yes, 4" overlap on sides and top of the arch.
3. Question: Regarding the 4in overlap how much clearance will be required between the fixed glazing and the adjacent material that is overlapping?  
Response: 1" is typical but the contactor makes the final determination.

Issued by: **Valerie L. Mitchell**  
Procurement Officer  
**04/08/2021**