



# Administrative Office of the Courts

---

## Operations Division

### Amendment #1

#### Small Procurement RFP JIS 300 – Wicomico County Circuit Court Electrical Services RH 29

This Amendment is being issued to amend and clarify certain information contained in the above-named Small Procurement RFP. All information contained herein is binding on all Offerors who respond to this Small Procurement RFP. Specific parts of the Small Procurement RFP have been amended. The following changes/additions are listed below; new language has been underlined (ex. new language) and language deleted has been marked with a strikeout (ex. ~~language deleted~~).

#### 1. Modify the following in Section 1.3 – Contractor Minimum Requirements

##### 1.3.1 License and Permits

Regardless whether a Low Voltage permit is required for work at this site, all work shall be performed in a “best practice” manner that complies with local, state and national codes. An electrical permit is required for this work.

#### 2. Modify the following in Section 1.4 – Statement of Work/Deliverables

1.4.1 In Courtroom 4, the Contractor shall supply and install one (1) working 110 VAC duplex receptacles supportive of a 4-amp load, at the videoconferencing location at a height of 84” and centered between the column and the door jamb.

1.4.2 In Courtroom 5, the Contractor shall supply and install one (1) working 110 VAC duplex receptacles supportive of a 4-amp load, at the videoconferencing location ~~at a height of 84”~~ adjacent to the existing duplex data outlet.

1.4.3 ~~In Courtroom 6, the Contractor shall supply and install two (2) working 110 VAC duplex receptacles. One (1) at the videoconferencing location at a height of 84” and supportive of a 4-amp load, and one (1) at the Witness box supportive of a 1-amp load.~~  
In Courtroom 6, the Contractor shall supply and install one (1) duplex outlet at the Videoconferencing location (Court Administrator shall verify exact location), supportive of 4-amp load. That outlet shall be a flush mounted floor box, 6AT Furniture Feed Evolution™ Poke Thru Device, Surface Style Cover, Aluminum, UPC Number – 6ATCFFAL.

1.4.2 Contractor’s Duties and Responsibilities:

d) Electrical outlets are not required to be dedicated.

Issued by Christos Bazekis  
Procurement Officer  
April 30<sup>th</sup>, 2021