



**ADMINISTRATIVE
OFFICE OF THE COURTS**

GOVERNMENT RELATIONS
INFORMATION TECHNOLOGY
INTERNAL AFFAIRS
JUDICIAL COLLEGE OF MARYLAND
OPERATIONS
PROGRAMS

Amendment #4

Request for Proposals

K16-0089-25

Renovations at Judicial Information Systems Building- First Floor (South)

This Amendment is being issued to amend and clarify certain information contained in the above named RFP. All information contained herein is binding on all Offerors who respond to this RFP. Specific parts of the RFP have been amended. The following changes/additions are listed below; new language has been underlined and language deleted has been marked with a ~~strikeout~~ (ex. ~~language deleted~~)

1. Revise Section 2.2- Scope of Work

10. The contractor shall install one (1) 20 amp, 120 volt circuit in the ceiling to each power pole location, the systems furniture vendor will provide and install the power pole.

11. The contractor shall install 20 amp, 120 volt circuits to wall boxes with each circuit feeding no more than four of the 11'-6" by 9' workstations.

12. The contractor shall install two (2) 20 amp, 120 volt circuits to each of the two wall boxes feeding the smaller workstations.

Issued by: Whitney Williams
Procurement Officer
April 19, 2016