



FRANK BROCCOLINA
STATE COURT ADMINISTRATOR
(410) 260-1295 Fax: (410) 974-2066
frank.broccolina@mdcourts.gov

FAYE D. MATTHEWS
DEPUTY STATE COURT ADMINISTRATOR
(410) 260-1257 Fax: (410) 974-2066
faye.matthews@mdcourts.gov

SHARON SAMPSON BALL
Executive Director
Human Resources
(410) 260-1283 Fax: (410) 974-2849
sharon.ball@mdcourts.gov

GRAY BARTON
Executive Director
Office of Problem-Solving Courts
(410) 260-3617 Fax: (410) 841-9850
gray.barton@mdcourts.gov

ROBERT BRUCHALSKI
Acting Executive Director
Judicial Information Systems
2661 Riva Road, Suite 900
Annapolis, Maryland 21401
(410) 260-1007 Fax: (410) 974-7170
robert.bruchalski@mdcourts.gov

ALLEN C. CLARK, III
Executive Director
Budget & Finance
(410) 260-1579 Fax: (410) 260-1290
allen.clark@mdcourts.gov

DAVID R. DURFEE JR.
Executive Director
Legal Affairs
(410) 260-1405 Fax: (410) 974-2066
david.durfee@mdcourts.gov

SUSAN HOWELLS
Executive Director
Procurement & Contract
Administration
(410) 260-1410 Fax: (410) 260-2520
susan.howells@mdcourts.gov

CONNIE KRATOVIL-LAVELLE
Executive Director
Family Administration
(410) 260-1296 Fax: (410) 974-5577
connie.kratovil-lavelle@mdcourts.gov

DIANE S. PAWLOWICZ
Executive Director
Court Research & Development
(410) 260-1725 Fax: (410) 974-2066
diane.pawlowicz@mdcourts.gov

JESSICA PITTS
Executive Director
Emergency Mgmt. & Court Security
(410) 260-3515 Fax: (410) 260-3524
jessica.pitts@mdcourts.gov

ROXANNE P. MCKAGAN
Director, Administrative Services
(410) 260-1407 Fax: (410) 974-2066
rocky.mckagan@mdcourts.gov

DEBORAH A. UNITUS
Director, Program Services
(410) 260-1291 Fax: (410) 260-3570
deborah.unitus@mdcourts.gov

**ADMINISTRATIVE OFFICE OF THE COURTS
MARYLAND JUDICIAL CENTER
2003 C COMMERCE PARK DRIVE
ANNAPOLIS, MARYLAND 21401**

**AMENDMENT #2
REQUEST FOR PROPOSALS
DATA CENTER BACK-UP POWER EQUIPMENT
PROJECT NUMBER K11-0096-29
MAY 23, 2011**

This Amendment is being issued to amend and clarify certain information contained in the above named RFP. All information contained herein is binding on all Offerors who respond to this RFP. Specific parts of the RFP have been amended. The following changes/additions are listed below; new language has been underlined and language deleted has been marked with a strikeout (ex. ~~language deleted~~).

1. Revise: RFP Section 2.1 as follows:

The data center currently receives an electrical feed of 400 kva with a maximum capability to receive 800 kva. Standby power is from a 150 KVA Liebert UPS and battery system, Onan automatic transfer switch and Onan ~~150 kva Onan~~ model 400 FEB 593 series generator.

Cooling is currently provided by ~~five~~ 5, 16-ton and 1, 5-ton Liebert HVAC systems.

Date Issued: May 24, 2011
Susan Howells, Procurement Officer

TTY Users: 1-800-735-2258

www.mdcourts.gov

