



ADMINISTRATIVE OFFICE OF THE COURTS

MARYLAND JUDICIAL CENTER
580 TAYLOR AVENUE
ANNAPOLIS, MARYLAND 21401

Pamela Harris
State Court Administrator
410-260-1295

Questions/Responses No. 5 to the Request for Proposal (RFP) K16-0011-25 Installation of Cell Phone Signal Boosters for Maryland Judiciary's Annapolis Complex

Ladies and Gentlemen:

The following questions for the above referenced RFP were received by e-mail and are answered and posted for all prospective Offerors who received the RFP. The statements and interpretations contained in the following responses to questions are not binding to the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Offeror asking the question.

25. Question: Can you provide the name of the roofing contractor who holds the maintenance contract for the roof?

Response: CentiMark Corporation holds the roof maintenance contract for Annapolis Commerce Park offices.

26. Question: In the Questions/Responses No. 4 document, question #17 suggests that there may be fiber available between **all** of the buildings but it may have to be "pulled" into the buildings and possibly repaired. Our original understanding is that there was only fiber available between 2 or 3 buildings. Please Clarify. Additionally, Network Maryland, a state run organization based in Annapolis, has fiber runs throughout the state. Has your office been in contact with this organization with regard to fiber that may be located at or near some of the facilities that that currently may not have fiber?

Response: We do not have much information on fiber between buildings. It is potentially between all buildings but is likely between two or three buildings. Where fiber is available, it may not be single mode and may need

repair.

JIS has been in contact with Network Maryland, and only one facility may have favorable location which may not help with tying multiple.

27. Question: In the Questions/Responses No. 3 document, question #8 asked about RF surveys in and around (outside) the buildings to which your office responded that the studies have been completed. How can we get a copy of those surveys?

Response: An error was made on Question and Response 3. No surveys of the interior or exterior of the building have been undertaken by the Judiciary.

28. Question: These buildings may have an existing warranty and maintenance contract through a roofing contractor. If so, will the roof work associated with this project (penetrations, patching) be done by the roofing contractor through coordination?

Response: Yes, the penetrations and patching of the roofs must be coordinated with and done by the roofing contractor identified by the landlord to preserve the roof warrantee.

Issued by: Khrystine Bunche, Procurement Officer

October 16, 2015