



Administrative Office of the Courts

Operations Division

Questions/Responses No. 2 to the

Request for Proposals (RFP)

District Court Rockville Digital Video Recorder System

K18-0075-84F

Ladies and Gentlemen:

The following questions for the above referenced RFP were received by the procurement officer and are answered and posted for all prospective Offerors. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Offeror asking the question.

- 1) **Question:** Shall the Owner wish to have the contractor to provide as-built drawings in the latest version of auto-cad format for this project? Please confirm.
Response: No

- 2) **Question:** Per section 2.2.3 Shall conduit pathway require for new cameras? Please confirm.
Response: No

- 3) **Question:** Who is responsible to provide PoE Network Switch for new cameras? Please confirm.
Response: Vendor must supply

- 4) **Question:** Per section 2.2.3 all the interior cameras are Network fixed Dome camera? Please confirm.

Response: See camera schedule

- 5) **Question:** Per section 2.2.3 all the exterior cameras are Network fixed Dome camera? Please confirm.

Response: See camera schedule

- 6) **Question:** Would you consider Vision Technologies to include surge protection for the exterior cameras field device and at the head-end rack-mount surge protection devices in our pricing proposal? Please confirm.

Response: Yes

- 7) **Question:** Per section 2.2.2 is there a requirement for new cameras recording? Please confirm.

Response: All cameras must record

- 8) **Question:** What is the proposed resolution, frame rate, codec utilized for camera recording storage, and How many days video retention? Please confirm.

Response: Minimum recording is 30 days.

- 9) **Question:** Are there any integration between CCTV VMS with any existing security system such as access control, intrusion detection system and intercom system? Please confirm.

Response: No

- 10) **Question:** We would like to know if any cameras will be required a lift for installation of the cameras. Please confirm.

Response: For installation : no; for replacement/repair – probably

- 11) **Question:** Per section 2.2.3, it is our understood that we shall only replace the old existing interior and exterior cameras only and use the existing pathway and existing cable. Please confirm.

Response: Yes, unless cabling is bad

12) Question: What is the manufacturer and model of camera that Owner wish to install for this project? Please verify.

Response: Install or Replace with a camera that is comparable to what is already there.

13) Question: Elevator cab camera EL-03-P3 which type of existing cable had been installed? Is it coaxial RG-59U?

Response: Cannot confirm this.

14) Question: Can you please provide how many Network fixed cameras and how many Network PTZ cameras currently Owner owed? What year was the CCTV camera system been installed?

Response: See camera schedule and 2010-2011

Date Issued: May 4, 2018

Issued by: April Molley, Procurement Officer