

# Administrative Office of the Courts Operations Division

## Questions/Responses No. 2 to the

#### Request for Proposals (RFP) #11142

### **Upper Marlboro Detention Center, Surveillance System Upgrade**

#### Ladies and Gentlemen:

The following questions for the above referenced RFP were received by e-mail and are answered and posted for all prospective Offerors. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Offeror asking the question.

1. Question: There are large book shelves behind the desks. Would they be

able to be moved in order to run cabling?

Response: No.

2. Question: Are there any restriction/guidelines for "wireless"

(Radio frequency) equipment?

District Court requires all hard wired devices Response:

3. Question: Would the government allow wireless door releases in this area?

Response: No

4. Question: Will an amendment be posted to include the details given at

the sitevisit?

Response: Yes, we have shared a Questions/ Responses No. 1 posted on the

Procurement website and <a href="https://emma.maryland.gov">https://emma.maryland.gov</a> (EMMA)

5. Question: In the Commissioner's Lobby, (1) existing camera will be

removed and replaced. (1) intercom will be installed next to the commissioners' entrance door 5 feet from the floor." ADA regulations state that an intercom should not be mounted higher than 48" from the floor if the intercom is accessible from the front and no more than 50" if the intercom is accessible from the side. We were wondering if the 5' measurement call out in the SOW was a typo and 50" was what was intended. Please provide

clarification.

Response: It is 5 feet from the floor.

6. Question: In the SOW it states "All cabling and monitors for the existing

surveillance system will be removed". Does the Administrative Office of the Courts (AOC) intend for the contractor to dispose of, i.e., recycle the cabling and monitors or is it the AOC's intent

to manage the assets after they are removed?

Response: The awarded contractor will only take cabling from the building

all devices will be collected by the project manager.

Issued by: Alisha Allmond

March 6, 2020